



JAS-ANZ



ISO 9001:2008
CERTIFIED

ISO 9001:2008 | ISO 14001:2015
OHSAS 18001-2007 Certified
Govt. Approved Lab

B-90, Shardapuri, Ramesh Nagar, New Delhi-110015

Tel. : 011-47081611, +91-8376945025

E-mail : info.apex2015@gmail.com

apextesting.researchlab2015@gmail.com

Website : www.atrl.in

TEST REPORT

Issued To : M/s. Vidya Niketan School,
D-Block, Saket,
New Delhi – 110017.

Nature of the : RO Water
Customer Ref. No : N.S
Brand Name : N.S
Sampling Method : N.S
Batch No. : N.S
Mfg. Date : N.S

Report /Sample No. : 2018060405
Date Of Receipt : 05.04.2018
Date of Issue : 10.04.2018
Test Started On : 05.04.2018
Test Completed on : 10.04.2018
Sample Quantity : 1 Ltr.
Sample Pkg. : Pet Bottle
Best Before Date : N.S
Any Other Information : N.S

S. No.	Test Parameters	Units of Measurements	Results	Requirement (IS: 10500-2012)	Method Reference
CHEMICAL PARAMETRES				Acceptable Limits	
1.	pH	—	6.98	6.5-8.5	IS: 3025(P-11)-1983
2.	Colour	Hazen	<5.0	5 Max.	IS: 3025(P-4)-1983
3.	Odour	—	Agreeable	Agreeable	IS: 3025(P-5)-1983
4.	Taste	—	Agreeable	Agreeable	IS: 3025(P-7&8)-1984
5.	Turbidity	NTU	<1.0	1 max.	IS: 3025(P-10)-1984
6.	Fluoride(as F)	mg/l	<0.1	1 max.	IS:3025 (P-60)-2008
7.	Calcium (as Ca)	mg/l	10.9	75 max.	IS: 3025(P-40)-1991
8.	Magnesium (as Mg)	mg/l	0.7	30 max.	IS: 3025(P-46)-1994
9.	Chloride (as Cl)	mg/l	7.4	250 max.	IS : 3025(P-32) 1988
10.	Sulphate (as SO4)	mg/l	0.9	200 max.	IS: 3025(P-24)-1986
11.	Total Dissolved Solids	mg/l	68.6	500 max	IS :3025(P-16)1984
12.	Total Hardness (as CaCo3)	mg/l	30.2	200 max	IS :3025(P-21)-2009
13.	Iron (as Fe)	mg/l	<0.1	0.3 max	IS:3025 (P-53)-2003
MICROBIOLOGICAL PARAMETERS					
1.	Coliform	MPN/100ml	Absent	Absent	IS:1622:1981
2.	E. coli	MPN/100ml	Absent	Absent	IS:1622:1981

Remarks: The sample confirm as per IS: 10500-2012 for water on parameters w. r. t. the above tests only

****End of Report****

Authorized Signatory
(Microbiological)

A. DAS
Principal
VIDYA NIKETAN
PRIMARY SCHOOL

Authorized Signatory
(Chemical)

Terms & Conditions : 1 Test reports are valid only for the samples tested in our laboratory. 2. Samples will be destroyed after 30 days from the date of issue of test reports unless otherwise specified. 3. Samples tested are Non-Returnable until specified at time of sample submission. 4. This report will not be valid for judicial purpose or for advertisement. 5. Any complaints about this report should be communicated in writing within 7 days of issue of this report. 6. Total liability of our laboratory is limited to invoiced amount.

Mr. Saeed Naqvi
Chairman
Managing Committee
Vidya Niketan